




32"-

5' DIA

0



METER

- 1. TO BE PURCHASED FROM THE DISTRICT AND INSTALLED BY THE DISTRICT
- 2. MINIMUM 5' DIAMETER CONCRETE MANHOLE WITH CEMENT BASE
- М OWNER IS TO PROVIDE A VALVE BEFORE PREVENTER (BFP) AFTER THE METER INSIDE OF THE PIT THE METER AND APPROVED BACKFLOW

COVER PLATE

- 1. COVER MUST WEIGH LESS THAN 170LBS
- 2. MINIMUM SIZE OF COVER WILL BE 32"
- 3. COVER TO CONFORM TO PAMREX 32MH OR EQUAL
- NOTES 4. DUCTILE IRON IRON COVER MARKED CLEARLY WITH "WATER" REQUIRED

- 1. THIS PIT IS TO BE PLACED ON PRIVATE PROPERTY NEAR THE STREET
 2. THIS TYPICAL PIT SHOULD BE DESIGNED FOR TRAFFIC LOAD
- INTERIOR FIXED LADDER REQUIRE, USE CAST IRON STEPS R1980 T NEENAH OR EQUAL. BOLTING TO BE INSTALLED IN VERTICAL AT 16" CENTERS
- BACKFLOW PREVENTER (BFP) TO MATCH SERVICE RISK FACTOR

REVISED 1/28/2013

WATER DISTRICT BRUNSWICK & TOPSHAM TOPSHAM, MAINE 04086 PO BOX 489



